

केन्द्रीय मुहर विभाग-2

संदर्भ :- के०मु०वि०-2/16: 3062

18-09-2026

विषय: पुनरीक्षित भा०मा० 3062: 2024 (संशोधन स ० 1 के साथ) के अनुपालन के दिशानिर्देश।

यह उपरोक्त विषय के संदर्भ में है।

सक्षम अधिकारी द्वारा अनुमोदित दिशानिर्देश अनुपालन हेतु संलग्न है।

सभी क्षेत्रीय/शाखा कार्यालयों से अनुरोध है की दिशानिर्देशों का तत्काल प्रभाव से अनुपालन सुनिश्चित करें।

(राहुल वर्मा)
वैज्ञानिक- डी

प्रमुख (के०मु०वि०-2)

सभी क्षेत्रीय/शाखाकार्यालय/प्रयोगशालाएँ/खाद्य एवं कृषि विभाग/प्रयोगशाला मान्यता एवं प्रबंधन विभाग

CENTRAL MARKS DEPARTMENT-2

Our Ref: CMD-2/16: 3062

18-09-2026

Subject: Guidelines for implementation of Revised IS 3062: 2024 with amendment no. 1.

This has reference to the subject mentioned above.

The Competent Authority has approved the enclosed Guidelines for implementation.

All ROs/BOs are requested to ensure the implementation of the above Guidelines with immediate effect.

(Rahul Verma)
Scientist-D

Head (CMD-2)

All ROs/BOs/Labs/FAD /LRMD

केन्द्रीय मुहर विभाग-2

संदर्भ :- के०मु०वि०-2/16: 3062

18-09-2026

विषय: पुनरीक्षित भारतीय मानक 3062:2024 (संशोधन संख्या 1 सहित) 'फसल संरक्षण उपकरण - रॉकर फुहारा - विशिष्ट और परीक्षण संहिता' एवं उत्पाद मैनुअल के कार्यान्वयन हेतु दिशा-निर्देश ।

1. IS 3062: 1995 (along with amendments 1 and 2) has been revised as IS 3062: 2024 (along with amendment no. 1) and has been published. The last date for implementation of the revised Standard with amendment is 08 October 2026 after which the old Standard shall stand withdrawn.
2. All BOs shall inform the Applicants and Licensees under their jurisdiction about implementation of the revised Standard within a week of issuance of these guidelines.
3. The significant changes (along with editorial corrections and referred IS update, as applicable) in the standard through this revision and subsequent amendment as listed in the Table are given for the purpose of general guidance.

Parameter	Clause No. as per IS 3062:1995, as amended	Clause No. as per IS 3062:2024, as amended	Effective Change
Test methods	11 (by reference to IS 10134:1994)	Clauses 11, 12 and relevant annexes	Test procedures consolidated into IS 3062.
Nozzle - types	6.9.4; requirements through IS 3652	6.9.4 and Annex G	Multi-hole nozzle is additionally provided for.
Nozzle spray distribution	6.9.4; IS 3652	Annex G, G-8	Detailed patternator test incorporated. Requirements for channels, test arrangement and collection are specified.
Nozzle endurance	6.9.4; IS 3652	Annex G, G-3.3	Detailed 48 h endurance requirement incorporated, including permissible variation in discharge and spray angle.
Declaration of component materials	4.1	4.4	Added declaration by the manufacturer in the manual.
Marking	9.1	9.1	Month and year of manufacture added.

4. Consequent upon the issuance of the revised Standard and amendment, the existing product manual has been revised which is being circulated separately.
5. The above guidelines come into force with immediate effect.

A. LICENSEES:

- i. The licensee shall implement the revised Standard with amendment no. 1 by 08 October 2026. Any difficulty in implementation shall be brought to the notice of CMD 2 at the earliest. BOs shall ensure that no Licences are under operation as per the old Standard after 08 October 2026. The status of implementation of the revised Standard shall be confirmed by Head (BO) to CMD-2 within two weeks of the last date of concurrent running.

- ii. The licensee shall submit evidence of conformity to the additional/modified requirements through In-house/Independent Test Reports as well as revised list of test equipment (as per Form 2), as applicable. Verification of implementation of the revised Standard, wherever required, shall be verified through a surveillance visit within 30 days of confirmation of implementation of the revised standard by licensee.
- iii. If the Licensee fails to complete all actions by 08 October 2026 it shall be dealt with as per the prevailing guidelines.

B. APPLICATIONS FOR GRANT OF LICENCE:

- i. Existing Applications where Sample has been submitted in the Laboratory/Test Report has been issued by the Laboratory may be processed as per the old Standard. However, if the Applicant is desirous of considering the Application as per the revised Standard, a declaration may be obtained from the Applicant to that effect and the Application may be processed accordingly. An undertaking shall from such Applicants also be obtained that if the sample fails while considering the provisions of the revised Standard, Licence will not be granted by BIS as per the old version.
- ii. Applications which are recorded henceforth may be processed as per the old Standard or the revised Standard. Processing of Applications as per the old Standard shall be permitted only up to 07 October 2026 and for such cases Applicant shall give a declaration that they will implement the revised Standard by 08 October 2026.
- iii. Beyond 08 October 2026 no Licence shall be granted as per the old Standard.

C. CHANGE IN SCOPE OF LICENCE:

- i. For change in scope of licence, the relevant provisions as given above for Applicants shall apply.
- ii. However, processing of such applications for change in scope of licence as per the old Standard shall be permitted only up to the date of implementation of the revised Standard or up to 08 October 2026 whichever is earlier.

6. उपरोक्त दिशा-निर्देश तत्काल प्रभाव से लागू होते हैं।

(राहुल वर्मा)

वैज्ञानिक- डी

प्रमुख (के०मु०वि०-2)

उप महानिदेशक (प्रमाणन)