



भारतीय मानक ब्यूरो

(उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय, भारत सरकार)

BUREAU OF INDIAN STANDARDS

(Ministry of Consumer Affairs, Food & Public Distribution, Govt. of India)

मानक भवन, 9, बहादुर शाह ज़फ़र मार्ग, नई दिल्ली - 110002

Manak Bhawan, 9, Bahadur Shah Zafar Marg, New Delhi - 110002

110002

Phones: 23230131 / 2323375 / 23239402

Website: www.bis.org.in / www.bis.gov.in

व्यापक परिचालन मसौदा

हमारा संदर्भ: सीईडी 44/टी-1

28 मई 2025

तकनीकी समिति : सिविल इंजीनियरिंग के कार्यों के मापन की पद्धतियाँ
(जल संसाधन विकास को छोड़कर) विषय समिति, सीईडी - 44

प्राप्तकर्ता :

- क) सिविल इंजीनियरी विभाग परिषद्, सीईडीसी के सभी सदस्य
- ख) सीईडी 44 व उसकी उपसमितियों, के सभी सदस्य
- ग) रूचि रखने वाले अन्य निकाय

प्रिय महोदय/महोदया,

निम्नलिखित भारतीय मानक का मसौदा संलग्न है:

प्रलेख संख्या	शीर्षक
सीईडी 44 (28109)WC	<p>भवन की माप की विधि एवं सिविल इंजीनियरिंग कार्य का भारतीय मानक मसौदा</p> <p>भाग 1 मिट्टी की खोदाई के काम</p> <p>[IS 1200 (भाग 1) का पांचवां पुनरीक्षण]</p> <p>ICS 17.020; 91.040.01; 93.010</p>

कृपया इस मानक के मसौदे का अवलोकन करें और अपनी सम्मतियाँ यह बताते हुए भेजे कि यदि यह मानक के रूप में प्रकाशित हो तो इस पर अमल करने में आपके व्यवसाय अथवा कारोबार में क्या कठिनाइयाँ आ सकती हैं।

सम्मतियाँ भेजने की अंतिम तिथि: 28/06/2025

सम्मति यदि कोई हो तो कृपया अधोहस्ताक्षरी को उपरिलिखित पते पर संलग्न फॉर्मेट में भेजें या

divya.s@bis.gov.in पर ईमेल कर दें।

यदि कोई सम्मति प्राप्त नहीं होती है अथवा सम्मति में केवल भाषा सम्बन्धी त्रुटि हुई तो उपरोक्त प्रलेख को यथावत अंतिम रूप दिया जाएगा। यदि सम्मित तकनीकी प्रकृति की हुई विषय समिति के अध्यक्ष के परामर्श से अथवा उनकी इच्छा पर आगे की कार्यवाही के लिए विषय समिति को भेजे जाने के बाद प्रलेख को अंतिम रूप दे दिया जाएगा।

यह प्रलेख भारतीय मानक ब्यूरो की वेबसाइट www.bis.gov.in पर भी उपलब्ध है।

धन्यवाद।

भवदीय,

(दिव्या एस.)

सदस्य सचिव सीईडी 44

वैज्ञानिक 'डी'(सिविल इंजीनियरिंग)

ई-मेल: divya.s@bis.gov.in

संलग्न: उपरिलिखित


भारतीय मानक ब्यूरो

(उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय, भारत सरकार)

BUREAU OF INDIAN STANDARDS

(Ministry of Consumer Affairs, Food & Public Distribution, Govt. of India)

मानक भवन, 9, बहादुर शाह ज़फ़र मार्ग, नई दिल्ली – 110002

Manak Bhawan, 9, Bahadur Shah Zafar Marg, New Delhi – 110002

Phones: 23230131 / 2323375 / 23239402

 Website: www.bis.org.in . www.bis.gov.in
WIDE CIRCULATION DRAFT
28 May 2025
Our Ref: CED 44/T-1
TECHNICAL COMMITTEE: Method of Measurement of Works of Civil Engineering
(Excluding Water Resources Development) Sectional Committee, CED 44

ADDRESSED TO:

- All Members of Civil Engineering Division Council, CEDC
- All Members of CED 44 and its Subcommittees
- All others interested

Dear Sir/Madam,

Please find enclosed the following document:

Doc No.	Title
CED 44 (28109)WC	Draft Indian Standard on Method of Measurement of Building and Civil Engineering Works Part 1 Earthwork [(Fifth Revision) of IS 1200 (Part 2)] ICS 17.020; 93.010

Kindly examine the draft standard and forward your views stating any difficulties which you are likely to experience in your business or profession, if this is finally adopted as National Standard.

 Last Date for comments: **28 June 2025**

 Comments if any, may please be made in the enclosed format and mailed to the undersigned at the above address or preferably through e-mail to divya.s@bis.gov.in.

In case no comments are received or comments received are of editorial nature, you will kindly permit us to presume your approval for the above document as finalized. However, in case of comments of technical in nature are received then it may be finalized either in consultation with the Chairman, Sectional Committee or referred to the Sectional Committee for further necessary action if so desired by the Chairman, Sectional Committee.

 The document is also hosted on BIS website www.bis.gov.in.

Thanking you,

Yours faithfully,

(Divya S.)

 Member Secretary CED 44
 Scientist 'D' (Civil Engineering)
 E-mail: divya.s@bis.gov.in

Encl: As above

FORMAT FOR SENDING COMMENTS ON BIS DOCUMENTS

(Please use A-4 size sheet of paper only and type within fields indicated. Comments on each clause/sub-clause/table/fig etc. be started on a fresh box. Information in column 3 should include reasons for the comments and suggestions for modified working of the clauses when the existing text is found not acceptable. Adherence to this format facilitates Secretariat's work) {Please e-mail your comments to divya.s@bis.gov.in}

Doc. No.: CED 44 (28109)WC

Title: Draft Indian Standard Method of Measurement of Building and Civil Engineering Works Part 1 Earthwork
[(Fifth Revision) of IS 1200 (Part 1)]

ICS 17.020; 93.010

LAST DATE OF COMMENT: 28 June 2025

NAME OF THE COMMENTATOR/ ORGANIZATION: _____

Clause/ Para/ Table/ Figure No. commented	Comments/Modified Wordings	Justification of Proposed Change

NOTE - Kindly insert more rows as necessary for each clause/table, etc

BUREAU OF INDIAN STANDARDS

DRAFT FOR COMMENTS ONLY

(Not to be reproduced without the permission of BIS or used as an Indian Standard)

Draft Indian Standard

METHOD OF MEASUREMENT OF BUILDING AND CIVIL ENGINEERING WORKS

PART 1 EARTHWORK

(Fifth Revision of IS 1200 part 1)

ICS 17.020; 93.010

Method of Measurement of Works of Civil Engineering
Sectional Committee, CED 44

Last date of comments
28 June 2025

FORWARD

(Formal Clause will be added later.)

Measurement occupies a very important place in the planning and execution of any civil engineering work from the time of first estimates to the final completion and settlement of payments for a project. Methods followed for measurement are not uniform and considerable differences exist between practices followed by different construction agencies and also between various Central and State Government departments. While it is recognized that each system of measurement has to be specifically related to administrative and financial organizations within a department responsible for the work, a unification of various systems at technical level has been accepted as very desirable, specially as it permits a wider range of operation for civil engineering contractors and eliminates ambiguities and misunderstandings of various systems followed.

Among various civil engineering items, measurement of buildings was the first to be taken up for standardization and this standard having provisions relating to building work was first published in 1958 and was subsequently revised in 1964. In its second revision. The standard was issued in different parts corresponding to different trades in building and civil engineering works. The third revision of the standard was published in 1974, and the fourth in 1992.

This revision has been brought out to incorporate the changes found necessary in light of usage of this standard and suggestions made by various implementing bodies. The

significant modifications in this revision are:

- a) The provision to measure work executed where utilities exist have been added;
- b) Clarification that underwater seepage is not to be measured separately and should be included in the description of the main item, has been added; and
- c) Shotcreting/sprayed concreting has been added to the list of special works.

This standard contributes to the Sustainable Development Goal 9 'Build resilient infrastructure, promote sustainable industrialization and foster innovation'.

For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a measurement shall be rounded off in accordance with IS 2 : 2022 'Rules for rounding off numerical values (second revision)'. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

Draft Indian Standard

**METHOD OF MEASUREMENT OF BUILDING AND CIVIL ENGINEERING WORKS
PART 1 EARTHWORK**

(Fifth Revision of IS 1200 part 1)

1 SCOPE

This standard (Part 1) covers the method of measurement of earthwork in building and civil engineering works.

2 GENERAL RULES

2.1 Bills of Quantities

The bills of quantities shall fully describe the materials and workmanship, and accurately represent the work to be executed.

2.2 Booking of Dimensions

In booking dimensions the order shall be consistent and generally in the sequence of length, breadth or width and height or depth or thickness.

2.3 Clubbing of Items

Items may be clubbed together provided that the break-up of the clubbed items is agreed to be on the basis of the detailed description of the items stated in this standard.

2.4 Measurements

Unless otherwise stated hereinafter all work shall be measured net in decimal system, as fixed in position as given below:

- a) Each dimension shall be measured to the nearest 0.01 m;
- b) Areas shall be worked out to the nearest 0.01 m²; and
- c) Cubical contents shall be worked out to the nearest 0.01 m³.

2.5 Work to be Measured Separately

Work executed in the following conditions shall be measured separately:

- a) Work executed in or under water,
- b) Work executed in or under foul situations,
- c) Work executed under tidal conditions,
- d) Work executed where utilities exist; and

e) Work executed in snow.

2.5.1 The levels of high and low water tides, where occurring, shall be stated.

2.6 The following works shall not be measured separately and allowance for the same shall be deemed to have been made in the description of main item:

- a) Setting out works, profiles, etc;
- b) Site clearance, such as cleaning grass and vegetation;
- c) Unauthorized battering or benching or excavation;
- d) Forming (or leaving) 'dead men' and 'tell tales' in borrow pits and their removal after measurements;
- e) Forming (or leaving) steps in sides of deep excavation and their removal after measurements;
- f) Excavation for insertion of planking and strutting;
- g) Unless otherwise specified, removing slips or falls in excavations; and
- h) Bailing out or pumping of water in excavation from rains or groundwater seepage.

3 CLASSIFICATION

The materials to be excavated shall be classified as follows unless otherwise specified.

- a) *Soft/Loose Soil* — Generally any soil which yields to the ordinary application of pick and shovel, or to *phawra*, rake or other ordinary digging implement; such as vegetable or organic soil, turf, gravel, sand, silt, loam, clay, peat, etc.
- b) *Hard/Dense Soil* — Generally any soil which requires the close application of picks, or jumpers or scarifiers to loosen; such as stiff clay, gravel, cobblestone, water bound macadem and soling of roads.

NOTE—Cobblestone is the rock fragment usually rounded or semi-rounded having maximum diameter in any one direction between 80 mm and 300 mm.

- c) *Mud* — A mixture of soil and water in fluid or weak solid state.
- d) *Soft/Disintegrated Rock (Not Requiring Blasting)* — Rock or boulders which may be quarried or split with crowbars. This will also include laterite and hard conglomerate.
- e) *Hard Rock (Requiring Blasting)* — Any rock or boulder for the excavation of which blasting is required.

NOTE — Boulder is a rock fragment usually rounded by weathering disintegration and exfoliation or abrasion by water or ice, having maximum diameter in any direction of more than 300 mm round lying loose on the surface or embedded in river bed soil, talus, slope wash and terrace material of dissimilar origin.

- f) *Hard Rock (Blasting Prohibited)* – Hard rock requiring blasting as described under (e) but where blasting is prohibited for any reason and excavation has to be carried out by chiselling, wedging or any other agreed method.

NOTE – A broad classification of soil and rock for earthwork suitable for conditions generally occurring in practice has been provided where necessary, further sub-classification may be done to suit Individual cases depending on the properties of the substrate.

4 METHOD OF MEASUREMENT FOR VARIOUS TYPES OF EXCAVATION

4.1 The measurement of earthwork shall be done in cubic metres, unless otherwise mentioned. The measurements to be taken shall be those of the authorized dimensions from which soil has been taken out and shall be measured without allowance for increase in bulk.

4.2 Excavation in Earthwork Including Rock Cutting

The measurement of excavation in earthwork including rock cutting shall be made as follows:

- a) Where the excavation is in trenches or from borrow pits in fairly uniform ground, the measurements of cutting trenches or borrow pits shall be made. 'Dead men' or 'tell-tales' may be left at suitable intervals to determine the average depth of excavation.
- b) Where the ground is not uniform, levels shall be taken before the start, after site clearance and after the completion of the work and the quantity of excavation in cutting computed from these levels.
- c) Where soft/disintegrated rock and hard rock are mixed the measurement for the total quantity shall be made by method (a) and/or (b) given above. The hard rock excavated shall be stacked and measured in stack. The quantity of the hard rock excavated shall be arrived at by applying pre-accepted deductions (stated as a percentage) for voids. From the total quantity of the mixture, the quantity of hard rock excavated thus arrived at shall be deducted to work out the quantity of the soft/disintegrated rock excavated.
- d) Where hard/dense soil, soft/disintegrated rock and hard rock are mixed, the measurement for the total quantity shall be made by methods (a) and/or (b) given above. If possible after the removal of the hard/ dense soil the levels of the exposed rocks surface shall be taken and the quantity of the hard/dense soil removed, worked out from the difference between the original levels and new levels. If this is not possible the excavation shall be completed leaving tell-tales and from the cross-section of these tell-tales, the area of the hard/dense soil excavated shall be worked out and then the volume of the hard/dense soil excavated arrived at. Quantity of hard dense soil shall then be deducted from the total quantity of hard

rock and soft/disintegrated rock. The quantities of hard rock and soft/disintegrated rock shall then be separated as in (c) above by stacking the hard rock separately.

- e) Where soft/loose soil, hard/dense soil, soft/ disintegrated rock and hard rock are mixed, the measurements of the entire quantity shall be made by methods (a) and/or (b) given above. The separate quantities of soft/loose soil and hard/dense soil shall be worked out from the cross-section based on dead men or tell-tales as mentioned in (d) in case of hard/dense soil. The total quantity of soft/loose and hard/dense soil shall then be deducted from the total excavation to arrive at the total quantity of rock excavated. The quantities of soft/ integrated rock and hard rock excavated shall be worked out separately as in case of (c) above.

4.2.1 Wherever it is not possible or inconvenient to take measurements from borrow pits or cutting, excavation shall be worked out from 'filling' (see **4.3**).

4.2.2 Dressing or trimming sides of excavations and levelling or grading and ramming of bottoms shall be described with the item of excavation except in the case of rough excavation (see **4.5**).

4.2.3 All excavation shall be measured in successive stages of 1.5 m stating the commencing level. This shall not apply to cases where no lift is involved as in hillside cutting.

4.2.4 All excavation shall generally be described as 'excavate and get out'. Getting out shall include throwing the excavated earth at least one metre or 1/3 depth (see Note) of excavation whichever is clearer of edge of the excavation. The subsequent disposal of surplus excavated material shall either be stated as a separate item or included with the item of excavation stating the lead.

NOTE — In special cases where disposal area is limited or where application of this requirement is impracticable, the person in-charge may adopt a berm of reduced width in any case not less than 600 mm provided the material being excavated is sufficiently stable and shoring is designed to carry the additional loads.

4.2.5 In case of the following works, authorized quantities (calculated on the basis of authorized working space) or those actually excavated, whichever, are less, shall be measured:

- a) In work which requires formwork;
- b) In work which will be covered externally with a damp proof covering;
- c) In work which will be covered externally with protective masonry work of brick, stone, precast concrete, etc;
- d) Trenches which are to receive post tensioned concrete ground beams;
- e) Special works like guniting, shotcreting/sprayed concreting etc; and
- f) In work which requires workmen to operate from outside.

4.2.5.1 Authorized working space shall be special in each case. Where authorized working space is not so specified the following shall apply:

600 mm measured from the face of substructure (including protective measures, if any) at lowest level, where extra working space is required. In addition, for item given in **4.2.5** (d) the extra length at each end shall be 1.5 m.

4.2.6 Battering and benching shall be specified and measured along with main item of excavation.

4.3 Filling

4.3.1 Actual measurement of fill shall be calculated by taking levels of the original ground before start of the work after site clearance and after compaction of the fill at suitable intervals and the quantity of fill computed from these levels.

4.3.2 Deductions shall be made from actual measurements in all cases of fills except for floors as in **4.12** to arrive at net measurement of filling based on pre-accepted or specified deduction (stated as percentage) for voids.

4.3.3 If the filling is obtained from the borrow pits it shall be measured from the borrow pits as 'excavation' (see **4.2**).

4.4 Surface Dressing

Trimming of natural ground, excavated surface and filled up area to remove vegetation and/or small inequalities not exceeding 150 mm deep shall be described as surface dressing and measured in square metres.

4.5 Rough Excavation

Excavation not requiring dressing of sides and bottom and reduction to exact levels, such as winning earth from borrow pits, hillside cutting, etc shall be described as rough excavation and measured in cubic metres.

4.6 Surface Excavation

Excavation exceeding 1.5 m in width as well as 10 m² on plan but not exceeding 300 mm in depth shall be described as 'surface excavation' and measured in square metres.

4.7 Excavation Over Area

Excavation exceeding 1.5 m in width as well as 10 m² on plan, and 300 mm in depth shall be described as excavation over areas and measured in cubic metres.

4.8 Excavation in Trenches for Foundations and for Pipes, Cables, etc

Excavation in trenches for foundations and for pipes, cables, etc, not exceeding 1.5 m in width and for shafts, wells, cesspits and the like, not exceeding 10 m² on plan shall be so described and measured in cubic metres.

4.8.1 The authorized quantities (calculated on the basis of authorized width) or those excavated, whichever is less, shall be measured in case of excavation for pipes, cables, etc. For the purpose of calculating the contents, cross-sections shall be taken at suitable intervals. The authorized width shall be specified in each case. (Relevant Indian Standards, if any, may be consulted for guidance).

4.8.2 *Excavation Trenches for Foundations*

For depth exceeding 1 m, an allowance of 50 mm/m depth for each side of trench shall be added to the specified width.

4.9 Post Holes

Independent post holes (or similar holes), each not exceeding 0.5 m², shall be enumerated and the description shall include return, fill and ram, and removal of surplus soil.

4.10 Return, Fill and Ram

Returning, filling and ramming of excavated earth where not described with the item of excavation shall be measured in cubic metres and shall include spreading in layers not exceeding 200 mm in depth, watering, well ramming and levelling.

NOTE – Compaction using mechanical means shall be so specified and measured separately

4.11 Embankments

Forming embankments and filling to make up levels shall be measured in cubic metres and shall include the formation of slopes. If the material is to be deposited in layers, this shall be described stating the thickness of such layers. The method of consolidation shall be described stating the degree of compaction required and mechanical means, if deployed. The measurement shall be taken in successive stages of 1.5 m stating commencing level. In case of special soils like marine clay, the allowance for change in the original levels due to load of an embankment shall be specified.

4.12 Filling under floors shall be measured in cubic metres and shall include spreading in layers not exceeding 200 mm in depth, watering, well ramming and levelling.

NOTE — Compaction using mechanical means shall be so specified and measured separately.

5 LEAD AND LIFT

5.1 Lead

The distance for removal shall be measured over the shortest practicable route and not necessarily the route actually taken. Distances not exceeding 250 m shall be measured in units of 50 m. Distances exceeding 250 m and not exceeding 500 m shall be measured as a separate item. Leads beyond 500 m shall be measured in units of 500 m, that is, there will be one item for lead exceeding 500 m and not exceeding 1 000 m, another item for lead exceeding 1 000 m and not exceeding 1500 m and so on up to 5 km. Where the lead exceeds 5 km, it will be measured in units of 1 km, half km and above be reckoned as one and less than half kilometer shall be ignored.

5.1.1 The description of items shall include loading and unloading.

5.1.2 If soil heaps requiring re-handling have become consolidated due to passage of time or any other reason, it shall be so stated and such heaps shall be measured separately.

5.1.3 For the purpose of measurements of lead, the area excavated shall be divided into suitable blocks and for each block the distance from the centre of the block to centre of placed earth pertaining to this block shall be taken as lead.

5.2 Lift

Lift shall be measured from ground level excavation up to 1.5 m depth below ground level and depositing excavated material on the ground shall be included in the item of earthwork for various kinds of soil. Extra lift shall be measured in unit of 1.5 m or part thereof. Obvious lifts shall only be measured; that is lifts inherent in the lead due to ground slope shall not be measured (except for lead up to 250 m).

When earth has to be carried over a bank/ obstruction and dumped beyond it, the lift shall be the difference in level between the centre of gravity of the excavated earth and the top of bank/construction.

6 PLANKING AND STRUTTING

6.1 The planking and strutting required to uphold the face of excavated earth, adjacent utility/structure etc, shall be measured in square metres of face supported, and grouped; separately in stages of 1.5 m.

6.1.1 The description shall include use and waste of all necessary timber work, including wales, struts and open or close poling boards, their fixing and subsequent removal.

6.1.2 Planking and strutting to the following shall be measured separately:

- a) Trenches;
- b) Areas (the description shall include use and waste of raking shores); and

c) Shafts, wells, cesspits, manholes and the like.

6.1.3 Where tightly driven close butt jointed sheeting is necessary as in the case of running sand, the item shall be measured separately and the packing of cavities behind sheeting with suitable material shall be included in description of the item.

6.1.4 Planking and strutting required to be left permanently in position shall be measured separately.

7 REMOVING TREES AND HEDGES

7.1 Clearing of shrubs, brushwood, small trees not exceeding 300 mm girth shall be measured in square metres, and shall deem to include removal and disposal. The girth shall be measured at 1 m above ground level.

7.2 Cutting down hedges and removal of fences shall be fully described and measured in running metres and shall deem to include removal and disposal.

7.3 Cutting down trees of 300 mm girth and over up to 1 000 mm girth shall be enumerated as one item. The cutting down of trees exceeding 1 000 mm in girth shall be enumerated stating the girth. The girth shall be measured at one metre above ground level. The item shall include lopping of branches and removal and disposal.

7.4 Digging out of roots including stacking shall be measured separately and enumerated.