



**DRAFT AMENDMENT NO. 1 MARCH 2024**  
**TO**  
**IS 18058: 2023 GUIDELINES FOR SUPERVISORY CONTROL**  
**AND DATA ACQUISITION (SCADA) SYSTEM DISPLAYS**

*[Page No .9, Table 3, Sl. No. (V) and (VI), col 3] Substitute the following for the existing.*

Line at 220 kV Voltage Level	 Lime Green (hex #00FF00; 0 Red, 255 Green and 0 Blue)
Line at 400 kV Voltage Level	 Red (hex #FF0000; 255 Red, 0 Green and 0 Blue)