

(PREVIEW)

Indian Standard

**BRASS GLANDS FOR PVC CABLES —
SPECIFICATION**

1 SCOPE

1.1 This standard covers requirements and dimensions for single compression brass glands for PVC cables of voltage grade up to and including 3.3 kV.

1.2 These glands are for general purpose applications for indoor use. The brass glands if used with suitable coating such as cadmium coating, can be used for other applications.

2 REFERENCES

2.1 The following Indian Standards are necessary adjuncts to this standard:

<i>IS No.</i>	<i>Title</i>
1885 (Part 32) : 1971	Electrotechnical vocabulary: (Part 32) : Part 32 Cables, conductors and accessories for electricity supply
2147 : 1962	Degrees of protection provided by enclosures for low-voltage switchgear and controlgear