

(PREVIEW)

Indian Standard

ANNEALED STRANDED COPPER CONDUCTORS FOR JUMPER WIRES — SPECIFICATION

1. SCOPE

1.1 This specification Covers the requirements for bare stranded annealed copper conductors of con-centric and rope lay (having concentric stranded members) construction for use as jumper wires in 25 kV ac at 50 Hz single phase traction overhead equipment.

REFERENCES

2.1 The following Indian Standards are necessary adjuncts to this standard:

<i>IS No.</i>	<i>Title</i>
IS 191 (Part 3) : 1980	Copper (<i>third revision</i>)
IS 1778 : 1980	Reels and drums for bare conductors (reaffirmed 1993)
IS 1885 (Part 32) : 1971	Electrotechnical vocabulary : Part 32 Cables, conductors and accessories for electricity supply