

(PREVIEW)

Indian Standard

GASEOUS FIRE EXTINGUISHING SYSTEMS — HCFC - 125 EXTINGUISHING SYSTEMS

1 SCOPE

1.1 This standard sets out specific requirements for the design and installation of total flooding fire extinguishing systems employing HCFC-125 gas extinguishant. This standard is applicable to single supply as well as distributed supply systems.

1.2 This standard complements various general requirements applicable to all types of gaseous fire-extinguishing systems (Halocarbon as well as Inert gas systems) listed in IS 15493. As such, both these standards should be read together before designing a system. Where requirements in both the standards differ, this standard shall take precedence.

1.3 This standard covers total flooding systems of HCFC-25 operating at nominal pressures of 2.5 MPa and 4.2 MPa only at 21°C.

2 REFERENCES

2.1 The standards given below contain provisions which through reference in this text constitute provisions of this standard. At the time of publication the editions indicated were valid. All standards are subject to revision and parties to agreements based on this standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below:

<i>IS No.</i>	<i>Title</i>
15493 : 2004	Gaseous fire extinguishing systems — General requirement