

(PREVIEW)

## *Indian Standard*

### **SPECIFICATION FOR DISTRIBUTION PILLARS FOR VOLTAGES NOT EXCEEDING 1 000 V AC AND 1 200 V DC**

#### **1. SCOPE**

**1.1** This standard covers the distribution pillars for voltages not exceeding 1 000 V ac or 1 200 V dc, the current rating in each outgoing or incoming current not exceeding 630 A, for use on ac or dc system, in outdoor conditions.

**1.2** This standard covers distribution pillars incorporating HRC type fuses only. It does not cover other equipment such as switches, miniature circuit breakers, instruments, etc.

**1.3** This standard also does not cover distribution fuse boards for which the provisions of IS : 2675-1983† shall apply.